



FECHA : 27-Jun-05

MUESTRA : PROPANO CAMION

CORRIDA N° : 13672

PROCEDENCIA : PLANTA SAN LUI

CALCULO POR COMPOSICION CROMATOGRAFICA

COMPOSICION		%MOLAR % VOLUM.			
C2	Etano	1,464	1,414		
C3	Propano	97,772	97,681		
IC4	Isobutano	0,733	0,870		
NC4	Nbutano	0,764	0,032	0,036	0,906
IC5	Isopentano	0,000	0,000		
NC5	Npentano	0,000	0,000		
TOTAL :		100,000	100,000		

CORROSION ASTM D-1836 :

HUMEDAD GPA Dryness test. :

T.V.R. (psig) ASTM D-1267 :

RES. VOLATIL (°C) ASTM D-1837 :

RES. MATERIAL (ml) ASTM D-1258 :

DENSIDAD A 15 °C :

0.505 Gr/cm³